



EWING TOWNSHIP FIRE DEPARTMENT Bureau of Fire Prevention

1666 PENNINGTON RD., EWING, NJ 08618

(609) 882-9885 Ext.112

Email - mnelson@ewingnj.org

November 05, 2024

Re: Name: Friends Forever Pet Crematory

Address: 1879 Pennington Rd.

Block: 496 Lot: 1

To: To Thom it may concern:

I have reviewed the Site Plan of the proposed building at 1879 Pennington Rd. I have listed the following concerns:

- 1) Site review plans don't show if this building is going to require a sprinkler system and/or required to have a Fire Alarm System? If the building is going to require a sprinkler system, I would recommend the following:
 - A. Provide a copy of the Utility plans where the Fire Department Connection "FDC" is to be installed on each of the buildings and if possible to be determined upon the construction of the development. Recommend having an "FDC" connection with a 5" Storz coupling with a 30-degree elbow. Installing an FDC sign above the connection. This will give ample space for the fire apparatus to safely hook up and remain outside the potential collapse zone in the event of a fire. We would maintain a 5' foot clearance of any landscape bushes or trees of the "FDC" connections.
 - B. When the fire alarm is installed, I would recommend selecting the locations of the fire alarm annunciator and/or alarm panel, and/or manual pull stations before being installed.
 - C. Please see attached regarding new fire code for mulch if was used around the buildings.
 - D. Site plans don't show the locations and height of the Knox Boxes to be installed on the buildings. Locations and heights are to be determined by the Fire Marshal's office upon construction.

If you have any questions or concerns, please feel free to contact me.

Respectfully submitted

Michael Nelson Fire Marshal

Ewing Twp. Fire Department Bureau of Fire Prevention